

18 Jan 2025

ADDENDUM/ CORRIGENDUM OF TENDER DOCUMENT

1. Refer para 5.1.5 Amendment of Tender Document (Rule 173(iii) of GFR 2017) of Manual for Procurement of Goods 2024.

2. Based on queries received from the environment. Following changes be made in the RFP for construction of pre-fabricated structures for **09 x Classrooms (Size 30 ft x 15 ft), incl 01 x Resources Room (Size 30 ft x 15 ft), 01 x Staff Room (Size 30 ft x 15 ft), 02 x Washroom (Size 08 ft x 15 ft & 08 ft Rooftop Covered Verandah** at Vajra Army Pre-Primary School, Jalandhar Cantt.

Ser No	Page Number	Clause	Prescribed in Tender	Modifications/Read as
(a)	1	Para 4(c)	Partition Wall thickness 60mm	Partition Wall thickness 50-60mm
(b)	2	Para 4(c) (iv)	The roof shall be made up of 50mm thick alongwith minimum 28 mm trapezoidal shape Panel.	The roof shall be sloped and made up of 50mm thick alongwith minimum 28 mm trapezoidal shape Panel.
(c)	2	Para 4(j)	Plinth level foundation	Plinth level concrete foundation
(d)	2	Para 4(k)	Electrical Fitment	Electric appliances to be made fully functional by the end of the construction.
(e)	3	Para 4 (l)(ii)	03 x urinal per washroom with allied accessories.	03 x urinal with allied accessories for Boys Toilet. 01 x western commode for each cubicle (Total qty 03) for Girls Toilet. The washrooms to be fully functional at the end of construction with 1000 Ltr water storage facility each.
(f)	3	Para 4(n)	Grid False Ceiling (White Colour)	Grid False Ceiling (White Colour) with ceiling height of 10 feet from floor.
(g)	3	Para 4(o)	Pathway in front of building	Pathway in front of building with ramp for each classroom.
(h)	3	Para 4	-	Following Point be added as Para 4 (r). MS Railing of 3 feet height to be fabricated alongside Verandah and ramp for safety purpose.
(j)	School Layout	-	Space for staircase	Space for open area.

3. The changes made as above will form part of tender document. The revised RFP is enclosed herewith for information and downloading. All other terms and conditions remain unaltered. Bidders are advised to submit the compliance matrix alongwith Technical Bid bringing out deviations from specifications if any. Quotations for commercial to include description of Items.